

**DIRECTORATE GENERAL OF HYDROCARBONS**

(Ministry of Petroleum & Natural Gas)

OIDB Bhawan, Plot No. 2, Sector 73, Noida-201301, India.

Phone: 0120-247 2000, Fax- 247 2049. email- mm@dghindia.gov.in

CORRIGENDUM NO. 3

In respect of National Competitive Bid Open Tender No. MM-14/2/2021-DGH/C-5478/ENQ-208 for “Renovation work in DGH office, Noida”, bid closing /Opening date is hereby extended from 07th February 2022 to 17th February 2022. The revised bid closing/opening time & date for the above tender is as under:

Bid Closing Date & Time : 17th February 2022 at 1400 Hrs (IST)

Bid Opening Date & Time : 18th February 2022 at 1500 Hrs (IST)

Reply to Pre-bid queries are also attached herewith.

Addendum/ Corrigendum / Bid Due Date Extensions, if any, to the Bid Documents shall be uploaded on aforementioned websites only. Hence, bidders shall view the said websites regularly.

HOD (MM)

For Directorate General of Hydrocarbons

Reponse to queries raised by bidders against Tender No. MM-14/2/2021-DGH/C-5478/ENQ-208

Sr. No.	Work Location	Reference Clause/ Page no. of bid document	Tender Clause	Query Raised by the bidder	DGH reply to queries through Corrigendum 2	Bidder queries/ observations of bidder on DGH reply published through Corrigendum 2	DGH Comments
1	-	-	-	We request to provide the preferred brands and model numbers of all the AV line items to meet the desired functionality. Also it will ensure that all the bidders are quoting the same thing and few inferior/Chinese brands are not entertained. At the moment, your tender documents does stop any brand to participate and there is a huge price gap between Brand A and Brand B.	Quoted products must meet the specifications mentioned in the tender. Vendor will have to commission & deliver an integrated solution with smooth functioning.	Their should be limit on the No of Brands . It is advisable to incorporate 2-3 brands/preferred make which match your specifications. Presently your specs are almost match even the Inferior brands which don't have the good performace as well as after sales services. By preferring , we can avoid the low category brands,	No Change
2	-	-	-	Since AV BOQ is pre designed, Please share the AV schematic drawings for each area/room for us to understand the exact Scope of work and estimate the bulk cable quantities.	>Vendor will have to design the solution based on the requirement & other details provided in the tender. >Vendor will have to provide documents as per para 53.3 under Documentation of the tender.	Your Tender is not allowing to amend the BOQ or make any changes, So we request you to please provide the detailed AV schematics / layouts with Elevations. This will reveal your expectations for AV installation with respect to design parameters.	Bidder may visit site for assessing the requirement.
3	-	-	-	Please share CAD drawings with floor plan, elevations and RCP for all the areas/rooms in our scope.	Floor plan, elevations and RCP for all the areas/rooms already attached Tender.	Same as above	Clarified in Corrigendum-2
4	-	-	-	It seems that the AV design of the Ground Floor Conference Hall has been copied in the Second floor conference hall while the size and seating capacity of both the halls are different, so please clarify.	Size & seating capacity are different for the 2 conference halls; however, AV Solution Design will be similar. Vendor may carry out site visit for assessing BoM requirement for individual hall. For Ground Floor Conference hall, new VC System has to be provided by the vendor while the existing Polycom RealPresence Group 500 VC System will have to be integrated with the Solution at 2nd Floor.	Your comments is Contradictory & not adhering to the BOQ. Eg. Polycom real resence group 500 will not compatible for We based VC , however, you have asked the same need in the Tender. , So we recommed you to consider the New Poly VC device.	>The requirement is for utilising single camera for VC & Web Conferencing Applications. In case, additional license/equipment are required in utilising the existing VC system to achieve this, the same will have to be considered, provided & integrated with the solution by the bidder. >Alternately, the bidder can provide an additional quantity of VC System that is quoted for Ground Floor Conference Hall to achieve the intended requirement. >The price for additional license/equipment may be suitably considered against Item 6.21 Any Other Item including Licenses etc in Price Bid

Sr. No.	Work Location	Reference Clause/ Page no. of bid document	Tender Clause	Query Raised by the bidder	DGH reply to queries through Corrigendum 2	Bidder queries/ observations of bidder on DGH reply published through Corrigendum 2	DGH Comments
5	Ground Floor Conference Hall	3.1.14 Page no. 88	The VC System will be equipped with two numbers of omni-directional microphones to be connected in daisy chain for complete coverage of voice of any member participating in the conference whenever he/she sings.	It is mentioned that the VC will have 2 nos. of microphones connected in daisy chain connection. In the detailed specs of VC system there is no additional microphone asked. Most of the VC devices come with the one microphone only.	The requirement is for two numbers of omni-directional microphones to be connected in daisy chain for complete coverage of voice of any member participating in the conference whenever he/she speaks. In case VC device comes with one microphone , one additional microphone with capabilities as mentioned is to be provided and installed by the bidder.	1. New VC comes with 1 Table MIC only , for additional Mic which is Costly , should be mentioned as separate line item in the BOQ. 2. How can the Vendor can quote the additional Mic for your existing Device bezz , their is no separate line mentioned in the Tender	The price for the same may be suitably considered against Item 6.21 'Any Other Item including Licenses etc' in Price Bid
6		3.1.20 Page no. 89	Matrix Switcher equipment, Digital Signal Processing System, Audio Amplifier, WIFI Access Point, LAN Switch, Transmitter/ Receiver and any other required equipment are to be supplied, installed & integrated as a single solution.	As per the detailed specifications of Matrix switcher, the no. of desired inputs and outputs are not available in one box with any of the OEM so please provide the preferred make and model for the same to avoid any discrepancy. Or if you wish to go with modular then we can configure.	Bidder to provide the Matrix switcher with adequate number of inputs and outputs for proper functioning of the solution. Entire solution has to be integrated as single solution. However, the equipments used may be of different OEMS. As per point 4 (Technical Specifications) of the Tender: The bidder will be required to provide free of cost & install all such items/ products that are not explicitly mentioned in the tender/ quoted by the bidder, but are essential to deliver integrated solutions as per requirement.	This is Contracdictory to your Tender. On one side you are liberating us to Design our own solution , on the other end, Tender has limitations to match your specs too. We have to discuss & explain you this.	Tender is not restrictive in nature. It provides minimum baseline requirement for the devices to be used. Based on your offered solution, in case higher specification is required, the bidder may quote the same.
7		Page No. 96 & 97	5. HDMI Distribution Amplifier: Qty – As per requirement/6. Multi Format Switcher Transmitter: Qty – As per requirement/7. HDMI Receiver: Qty – As per requirement	Qty. mentioned as "As per requirement" whereas on Page No.138 Price schedule the quantity shown "1" so please clarify the required quantity.	Bidder may conduct a survey before bidding for assessing the required number as per the capabilities of the quoted equipment.	If you provide AV schemnatic , then the required qty can be figure out	>As already clarified in Corrigendum-2, the bidder may visit site for assessing the requirement. >The tender provides minimum baseline requirement for the devices to be used. Based on your offered solution, in case more quantity is required, the same has to be provided & integrated with the solution. >The price for additional equipement may be suitably considered against Item 6.21 Any Other Item including Licenses etc in Price Bid
8		Page No. 98	9. Cable Cubby: Qty – 7(Seven) "Certification Must be UL and CE listed"	The certifications asked seem to be available only in Extron and no other brand. It should be removed to make choices available for DGH and also only importing Extron may not be practically possible.	Clarified that Certification must be UL or CE listed	Since it's a passive item , so these type of certifications restrict to explore the best economical & suitable option. We request to please remove these certifications	No Change

Sr. No.	Work Location	Reference Clause/ Page no. of bid document	Tender Clause	Query Raised by the bidder	DGH reply to queries through Corrigendum 2	Bidder queries/ observations of bidder on DGH reply published through Corrigendum 2	DGH Comments
9	Ground Floor Conference Hall	Page No. 102	17. Digital Sound Processor: Qty – 1(One)	As per the specification given in the tender document, DSP asked with 12 Mic/Line AEC inputs whereas total no. of microphones are 16 (11 Table Mics + 2 Lepal+2 Handheld Mics). The mentioned specs are not sufficient to connect all the 16 microphones to this DSP.	As per point 4 (Technical Specifications) of the Tender: The bidder will be required to provide free of cost & install all such items/ products that are not explicitly mentioned in the tender/ quoted by the bidder, but are essential to deliver integrated solutions as per requirement.	You should have consider 2 No of DSP instead of 1 two connect all the microphones. Since this is a Costly Item so this cannot be Assumed & absorbed	>The tender provides minimum baseline requirement for the devices to be used. Based on your offered solution, in case more quantity is required, the same has to be provided & integrated with the solution. >The price for additional equipement may be suitably considered against Item 6.21 Any Other Item including Licenses etc in Price Bid
10	Second Floor Conference Hall	3.2.4 Page no. 90	2. The existing Polycom RealPresence Group 500 Video conferencing (VC) system to be integrated with the AV Solution.	As mentioned existing Polycom VC device will be used whereas in Figure4, you have not shown it as existing VC. In the detailed specs sheet you have asked for VC system which can be used for web based VC conferencing. A sits the existing VC, so web based VC will be enabled? Polycom RealPresence Group 500 is IP based VC system only and cannot be use for Web based VC calls in BYOD mode.	The requirement is for utilising same camera for VC & Web Conferencing Applications. In case, additional license/equipement are required in utilising the existing VC system to achieve this, the same will have to be considered, provided & integrated with the solution by the bidder. Alternately, the bidder can provide an additional quantity of VC System that is quoted for Ground Floor Conference Hall to achieve the intended requirement. The price for the same may be suitably considered against Item 6.21 Any Other Item including Licenses etc in Price Bid.	Your comments is Contradictory & not adhering to the BOQ. Eg. Polycom real resence group 500 will not compatible for We based VC , however, you have asked the same need in the Tender. , So we recommed you to consider the New Poly VC device.	>The requirement is to single camera for VC & Web Conferencing Applications. >The bidder may provide an additional quantity of VC System that is quoted for Ground Floor Conference Hall to achieve the intended requirement. The price for the same may be suitably considered against Item 6.21 'Any Other Item including Licenses' etc in Price Bid.
11		3.2.7 Page no. 91	The PTZ camera of the VC system will be used as a common camera for both the VC and Web Conferencing applications. Necessary licenses and any equipment including converters etc. required to achieve this have to be considered, provided & integrated with the solution by the bidder.				

Sr. No.	Work Location	Reference Clause/ Page no. of bid document	Tender Clause	Query Raised by the bidder	DGH reply to queries through Corrigendum 2	Bidder queries/ observations of bidder on DGH reply published through Corrigendum 2	DGH Comments
12	Second Floor Conference Hall	3.2.9 Page no. 91	Table-top boundary layer microphones should capture the local user's speech and transmit to the ceiling speakers during a local meeting/ presentation session. VC System Microphones, 2 numbers daisy chain connected for better coverage, should capture the local user's speech and transmit to far end during a Video conferencing calls.	Hope you existing VC system will have 2 mikes available?	Existing VC system has only one No of Mic.Our requirement is for two numbers of omni-directional microphones to be connected in daisy chain for complete coverage of voice of any member participating in the conference whenever he/she speaks. In this case one additional microphone with capabilities as mentioned is to be provided and installed by the bidder.	How can the Vendor can quote the additional Mic for your existing Device becZ , their is no separate line mentioned in the Tender	The price for the same may be suitably considered against Item 6.21 Any Other Item including Licenses etc in Price Bid
13		Page No. 108 & 109	4. HDMI Distribution Amplifier: Qty – As per requirement/5. Multi Format Switcher Transmitter: Qty – As per requirement/6. HDMI Receiver: Qty – As per requirement	Qty. mentioned as "As per requirement" whereas on Page No.148 Price schedule the quantity shown "1" so please clarify the required quantity.	Bidder may conduct a survey before bidding for assessing the required number as per the capabilities of the quoted equipment.	If you provide AV schematic , then the required qty can be figure out	>As already clarified in Corrigendum-2, the bidder may visit site for assessing the requirement. >The tender provides minimum baseline requirement for the devices to be used. Based on your offered solution, in case more quantity is required, the same has to be provided & integrated with the solution. >The price for additional equipment may be suitably considered against Item 6.21 Any Other Item including Licenses etc in Price Bid
14		Page No. 109 & 110	8. Cable Cubby: Qty – 3(Three) "Certification Must be UL and CE listed"	The certifications asked seem to be available only in Extron and no other brand. It should be removed to make choices available for DGH and also only importing Extron may not be practically possible.	Clarified that Certification must be UL or CE listed	Since it's a passive item , so these type of certifications restrict to explore the best economical & suitable option. We request to please remove these certifications	No Change
15		Page No. 113	15. Digital Sound Processor: Qty – 1(One)	As per the specification given in the tender document, DSP asked with 12 Mic/Line AEC inputs whereas total no. of microphones are 14 (11 Table Mics + 2 Lepel Mics). The mentioned specs are not sufficient to connect all the 16 microphones to this DSP.	As per point 4 (Technical Specifications) of the Tender: The bidder will be required to provide free of cost & install all such items/ products that are not explicitly mentioned in the tender/ quoted by the bidder, but are essential to deliver integrated solutions as per requirement.	You should have consider 2 No of DSP instread of 1 two connect all the microphones. Since this is a Costly Item so this cannot be Assumed & absorbed	The price for any additional item/quantity, if necessary, may be suitably considered against Item 6.21 'Any Other Item including Licenses etc' in Price Bid

Sr. No.	Work Location	Reference Clause/ Page no. of bid document	Tender Clause	Query Raised by the bidder	DGH reply to queries through Corrigendum 2	Bidder queries/ observations of bidder on DGH reply published through Corrigendum 2	DGH Comments
16	Fourth Floor Conference Hall	3.3.2 Page no. 92	Figure-5, Block schematic of Fourth floor conference hall	The figure shows that there is existing Polycom RealPresence Group500 VC system. This VC system is IP based VC device only and cannot be used for PC/Web based VC application in BYOD Mode.	There is no VC equipment in the Conference Room.For Web Conferencing camera and mic of PC/Laptop to be used.	Not asked in the BOQ Tender.	Clarification already provided
17				It shows Web conferencing PC/Laptop in block diagram whereas existing Polycom VC devise cannot be use for the same.	There is no VC equipment in the Conference Room.For Web Conferencing camera and mic of PC/Laptop to be used.		
18	-	-	Bid submission by 1400 hrs. on 13.01.2022	Please extedn the Bid , Post 1 week from the date of submission of the queries.	Bid closing date is extended to 07.02.2022.	Request to please extend the Tender Till all the Technical queries gets clarified	Bid closing date is extended till 17.02.2022, 14:00 IST.