



DIRECTORATE GENERAL OF HYDROCARBONS
(Ministry of Petroleum & Natural Gas)
OIDB Bhawan, Plot No. 2, Sector 73, Noida-201301, India.
Phone: 0120-247 2000, Fax- 247 2049. eMail- mm@dghindia.org


Addendum No. 1 dt. 22.01.2016 to
Bid Document No. DGH/MM/Admin/Steel Optimizer/224/ 2015/ ENQ/014
for Supply & Installation of 14 units of Steel Mobile Compactor Filing
System on rails also known as Optimizer / Movable racks / Shelves.



DGH has received following queries /Clarifications / modifications requests from various prospective bidders during its pre-bid conference. After careful examination of the same, DGH has gives its reply as in the last column of the table below. Please be guided accordingly, while making your bid.


| Sl | Ref. in Tender | Queries raised in brief | DGH's Reply |
|----|--|--|---|
| 1 | Annexure-II(B.1) (2.1) | Tender PQC specifies BIFMA which is essentially a membership for furniture manufacturers, and does not apply to Storage systems and hence, not applicable in the instant case. | After detailed deliberations, DGH has decided to maintain the requirement. Accordingly, relevant Clauses of the tender remain unchanged. |
| 2 | Annexure-IV (2)(A)(b) and in Price Formats | Whether total height of the system can be 2580 mm | Due to technical reasons, DGH is not in a position to allow accept height more than 2362 as already stipulated. 2362 is the height of the body only and the height of rail & undercarriage will be extra. |
| 3 | Annexure-IV (2)(D)(c) / (e)(ii) | Whether M-section can be provided, Instead of J-section. | Yes. |
| 4 | Annexure-IV (2)(A)(c) & (C)(d) | Whether the Optimizers / Compactors should be fire resistant; If so, any change / addition in specification required. | DGH has already stipulated epoxy polyester powder coating of approved colour, in this regard. |
| 5 | Annexure-III (14) | Whether any stage inspection at site required at works / factory | Stage inspection will be done at works/factory, prior to the painting of the system to ensure the basic compliance of the scope of work/specification. |
| 6 | Pages 1&2 | Bid Closing / Opening Date | Stands extended to 18.02.2016. |
| 7 | All other terms & conditions remain unchanged. | | |


All other specifications, terms & conditions remain unchanged.

HoD (MM)
For: Director General of Hydrocarbons.











Optimizer-10




Site- Second Floor Qbical side

Optimizer-11



Site- Second Floor Near T2 side



Site- Third Floor Nelp data Room